



**Environmental and Laboratory Services**  
 90 ½ West Blackwell Street, Dover, New Jersey 07801  
 (973) 989-0010 P, (973) 989-0156 F

***Analytical Results***

Report Issued: October 20, 2016  
 Client: Montclair Water Bureau  
 Address: 54 Watchung Ave.  
 Montclair, NJ 07043  
 PWSID#: NJ0713001

**Project: Linden Ave School**

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWSC2246-1  
 Sample location: Basement-Near Boiler Room  
 Sampled by: Client  
 Sample date: 10/13/16  
 Time: 06:45  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	10/17/16	22:26	2 ug/L
Copper	SM3111B	0.483 mg/L	1.3 mg/L	10/19/16	11:47	0.05 mg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWSC2246-2  
 Sample location: 1<sup>st</sup> Floor-Hallway by Front Entrance  
 Sampled by: Client  
 Sample date: 10/13/16  
 Time: 06:40  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	10/18/16	00:11	2 ug/L
Copper	SM3111B	0.461 mg/L	1.3 mg/L	10/19/16	11:48	0.05 mg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWSC2246-3  
 Sample location: 2<sup>nd</sup> Floor-By Room 12 & Teachers Room  
 Sampled by: Client  
 Sample date: 10/13/16  
 Time: 06:50  
 Analyst: C. Malone

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	10/18/16	00:18	2 ug/L
Copper	SM3111B	0.340 mg/L	1.3 mg/L	10/19/16	11:48	0.05 mg/L

ug/L = micrograms per liter  
 mg/L = milligrams per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Lawrence Chang (For SV)  
Susan Van Veen, Laboratory Manager  
NJ Laboratory Certification ID # 14013

October 20, 2016  
Date

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: <u>MONTECLAIR WATER</u>	report to:	Agra Environmental Services
Address: <u>54 WATCHING AVE</u>		90½ West Blackwell Street
County/Municipality: <u>MONTECLAIR, NJ</u>		Dover, NJ 07801
Phone: <u>973-744-4600 x-3013</u>		Phone: (973) 989-0010
Work:		Fax: (973) 989-0156



Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project: <u>LINDEN AVE SCHOOL</u>		Collection		PWSID# NJ					for laboratory use only	Field Analysis
Field ID	Lab ID	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	
<u>DWSC2246</u>										
<u>BASEM - NEAR BOILER ROOM</u>		<u>10/13/16</u>	<u>6:45</u>	<u>X</u>		<u>D</u>	<u>1</u>		<u>CJ PB Pb &lt;2 mg/L 10/17 2226 CM</u>	
<u>1<sup>ST</sup> FL - HALLWAY BY FRONT ENT</u>		<u>1</u>	<u>6:40</u>	<u>X</u>		<u>D</u>	<u>1</u>		<u>1 &lt;2 mg/L 10/18 0011 1</u>	
<u>2<sup>ND</sup> FL. BY ROOM 12 &amp; TEACHERS ROOM</u>		<u>7</u>	<u>8:50</u>	<u>X</u>		<u>D</u>	<u>1</u>		<u>1 &lt;2 mg/L 1 0018 1</u>	
									<u>CJ 0.483 mg/L 10/19 1147 CM</u>	
									<u>1 0.461 mg/L 1 1148 1</u>	
									<u>1 0.340 mg/L 1 1148 1</u>	

Sampled By (name/company): <u>Tommy Perrina</u>	State Forms Needed (circle one): Yes or <u>No</u>		indicate laboratory location where analysis requested was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013		
	NJDEP Laboratory Certification (Marlboro, NJ) #13033		

Reporting Requirements (Check Box):	<input type="checkbox"/> Standard	<input type="checkbox"/> NJ Reduced	<input type="checkbox"/> Other (Specify)	Cooler Temperature Upon Receipt at lab:
-------------------------------------	-----------------------------------	-------------------------------------	--	---

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <u>Tommy Perrina</u>	Date: <u>10/13/16</u>	Time:	Received By: <u>Sherry Pate</u>	Date: <u>10/13/16</u>	Time: <u>0901</u>	<u>acidified 10/13/16 0925</u>
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No