



Environmental and Laboratory Services  
 90 ½ West Blackwell Street, Dover, New Jersey 07801  
 (973) 989-0010 P, (973) 989-0156 F

## Analytical Results

Report Issued: April 8, 2016  
 Client: Montclair Water Bureau  
 Address: 54 Watchung Ave.  
 Montclair, NJ 07043

PWSID#: NJ0713001

**Project: Ridgewood School**

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWSC1320-1  
 Sample location: Water Fountain by Room 123 (No Filter)  
 Sampled by: Client  
 Sample date: 03/29/16  
 Time: 03:45  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	04/06/16	20:06	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWSC1320-2  
 Sample location: Water Fountain by Room #223 (Filter)  
 Sampled by: Client  
 Sample date: 03/29/16  
 Time: 03:45  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	04/06/16	20:12	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWSC1320-3  
 Sample location: Teacher's Room  
 Sampled by: Client  
 Sample date: 03/29/16  
 Time: 03:45  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	04/06/16	20:18	2 ug/L

ug/L = micrograms per liter


All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)  
Susan VanVeen, Laboratory Manager  
NJ Laboratory Certification ID # 14013

April 11, 2016  
Date



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: <b>Montclair Water Bureau</b>	Report To: _____	<b>Agra Environmental Services</b>
Address: <b>54 Watchung Ave.</b>	<b>Gary Obszarny</b>	90½ West Blackwell Street
<b>Montclair, NJ 07043</b>		Dover, NJ 07801
County/Municipality: _____		Phone: (973) 989-0010
Phone: <b>973-744-4600 ext. 3013</b>		Fax: (973) 989-0156
Work: <b>973-233-1826</b>		

**Matrix Abbreviations:** D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page \_\_\_\_\_ of \_\_\_\_\_

Project: <b>Ridgewood School</b>	Collection	PWSID# <b>NJ0713001</b>						for laboratory use only	Field Analysis		
Field ID	Lab ID: <b>DW5C1320</b>	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Cl <sub>2</sub>	pH/T°C
1		<b>3/29/16</b>	<b>3:45</b>	<b>X</b>		<b>D</b>	<b>1</b>		<b>Lead &lt; 2 mg/L 4/6 2006 BM</b>		
2		<b>3/29/16</b>	<b>3:45</b>	<b>X</b>		<b>D</b>	<b>1</b>		<b>Lead &lt; 2 mg/L 2012</b>		
3		<b>3/29/16</b>	<b>3:45</b>	<b>X</b>		<b>D</b>	<b>1</b>		<b>Lead &lt; 2 mg/L 2018</b>		

Sampled By (name/company):	State Forms Needed (circle one): Yes or No	indicate laboratory location where analysis requested was performed
	<input type="radio"/> Yes <input type="radio"/> No	
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard <input type="checkbox"/>	NJ Reduced <input type="checkbox"/>
		Other (Specify) _____
		Cooler Temperature Upon Receipt at lab: _____

<b>Sample Custody Exchanges (Please use full legal signature)</b>						Scanned _____
Relinquished By: 	Date: <b>3-29-16</b>	Time: <b>8:35</b>	Received By: 	Date: <b>3/29/16</b>	Time: <b>0835</b>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No