



**GLEN RIDGE PUBLIC SCHOOLS
LEAD IN DRINKING WATER
FIRST DRAW SAMPLING REPORT**

PERFORMED FOR:

GLEN RIDGE PUBLIC SCHOOLS
12 HIGH STREET
GLEN RIDGE, NJ 07028

PERFORMED BY:

WESTCHESTER ENVIRONMENTAL LLC
1248 WRIGHTS LANE
WEST CHESTER, PA 19380

DECEMBER 2021



December 16, 2021

Mr. John Baumann
Glen Ridge Public Schools
12 High Street
Glen Ridge, NJ 07028

Re: LEAD IN DRINKING WATER REPORT- FIRST ROUND SAMPLING

Dear Mr. Baumann

Please find enclosed the report for the Lead in Drinking Water-First Draw Sampling conducted for Glen Ridge Public Schools.

If you have any questions, please contact me at 610-431-7545 or email me at nabraham@westchesterenvironmental.com.

Sincerely,

Westchester Environmental, LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', is written over a horizontal line.

Noel Abraham
Environmental Specialist



TABLE OF CONTENTS

GLEN RIDGE PUBLIC SCHOOLS

1.0	INTRODUCTION.....	1
2.0	SUMMARY OF FINDINGS.....	2
3.0	SAMPLING AND ANALYSES.....	5
4.0	DISCUSSION & RECOMMENDATIONS.....	6
5.0	DISCLAIMER.....	7

Appendix I – Water Sampling Chain-of-Custody & Laboratory Reports



1.0 INTRODUCTION

Westchester Environmental, LLC was contracted by Mr. John Baumann to conduct Drinking Water Sampling at the following Glen Ridge Public Schools:

1. Central School
2. Linden Avenue School
3. Forest Avenue School
4. Board of Education Administration Office
5. Ridgewood Avenue School
6. Glen Ridge High School

The purpose of the sampling was to collect first draw drinking water samples at predetermined locations in the six facilities and have them analyzed for lead levels.

The water sampling was performed on November 4, 2021 by Noel Abraham and Biju Joseph of Westchester Environmental, LLC.

All samples were analyzed by Suburban Testing Labs located at 1037 MacArthur Rd, Reading, PA 19605, a New Jersey certified Lead in Drinking Water testing facility.

-END OF SECTION-



2.0 SUMMARY OF FINDINGS

First Draw samples were collected and submitted for lead analysis. Tables 1- 6 below shows the concentration of lead (parts per billion or microgram per liter) at each location sampled.

Table 1: Central Elementary

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
1	GRC-POE-Nurse	<1.00	15.5	No
2	GRC-1FL-NS-Nurse	<1.00	15.5	No
3	GRC-1FL-BF-O/S Nurse - 2	<1.00	15.5	No
4	GRC-1FL-BF-O/S Handicap BR	<1.00	15.5	No
5	GRC-1FL-FS-Teacher's Lounge	<1.00	15.5	No

Table 2: Linden Avenue Elementary

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
6	GRLE-B-POE-B2	<1.00	15.5	No
7	GRLE-B-WCC-O/S BOILER RM	<1.00	15.5	No
8	GRLE-WCF-Nurse (B5)	<1.00	15.5	No
9	GRLE-B-WCF-Cr 16W	2.95	15.5	No
10	GRLE-1FL-WCF-Cr 17W	<1.00	15.5	No
11	GRLE-1FL-WCF-Cr 6	<1.00	15.5	No
12	GRLE-1FL-WCF-Cr 6 BR	3.36	15.5	No
13	GRLE-1FL-WCC-O/S CR 1	<1.00	15.5	No
14	GRLE-1FL-WCF-CR 3	1.34	15.5	No
15	GRLE-1FL-WCF-CR 3 BR	2.22	15.5	No
16	GRLE-GRLE-1FL-WCF-CR 4	<1.00	15.5	No
17	GRLE-1FL-WCF-CR 5	<1.00	15.5	No
18	GRLE-2FL-WCF-Teachers' Lounge	<1.00	15.5	No
19	GRLE-2FL-WCC-O/S Teachers' Lounge	<1.00	15.5	No
20	GRLE-2FL-WCF-CR 14	<1.00	15.5	No



Table 3: Forest Avenue Elementary

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
21	GRFE-POE-Gym	<1.00	15.5	No
22	GRFE-B-WCC-Gym	<1.00	15.5	No
23	GRFE-B-WCF-Exit 2	<1.00	15.5	No
24	GRFE-1FL-WCF-W4	<1.00	15.5	No
25	GRFE-1FL-WCF-W3	<1.00	15.5	No
26	GRFE-1FL-WCF-W2	11.1	15.5	No
27	GRFE-1FL-WCF-W1	<1.00	15.5	No
28	GRFE-1FL-WCC-O/S W1	<1.00	15.5	No
29	GRFE-2FL-WCC-O/S 9	<1.00	15.5	No

Table 4: BOE Administration Office

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
30	GRA-Bsmt-POE-Slop Sink	2.29	15.5	No
31	GRA-1FL-WCF-1st Fl	1.01	15.5	No
32	GRA-3Fl-WCF-3rd Fl	<1.00	15.5	No

Table 5: Ridgewood Avenue Elementary

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
33	GRRE-B-POE-Art	<1.00	15.5	No
34	GRRE-B-WCC-O/S Gym	<1.00	15.5	No
35	GRRE-B-WCF-Teachers' Lounge (20)	<1.00	15.5	No
36	GRRE-Mez-WCC-O/S Gym	<1.00	15.5	No
37	GRRE-1FL-WCF-Nurse	<1.00	15.5	No
38	GRRE-1FL-WCF-Office 101	<1.00	15.5	No
39	GRRE-1FL-WCC-O/S 123	<1.00	15.5	No
40	GRRE-2FL-WCC-O/S 222	<1.00	15.5	No
41	GRRE-2FL-WCC-O/S 208	<1.00	15.5	No
42	GRRE-2FL-WC1-Café - 1	<1.00	15.5	No
43	GRRE-2FL-S-Café - 2	<1.00	15.5	No
44	GRRE-2FL-CF1-Kitchen - 1	<1.00	15.5	No
45	GRRE-2FL-CF1-Kitchen - 2	7.97	15.5	No
46	GRRE-2FL-CF1-Kitchen - 3	<1.00	15.5	No
47	GRRE-2FL-CF1-Kitchen - 5	<1.00	15.5	No
48	GRRE-2FL-CF1-Kitchen - 6	<1.00	15.5	No
49	GRRE-2FL-CF1-Kitchen - 7	<1.00	15.5	No



Table 6: Glen Ridge High School

Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
50 GRHS-B-POE-Art Sink	<1.00	15.5	No
51 GRHS-1FL-WCF-Nurse (121)	<1.00	15.5	No
52 GRHS-1FL-WCF-Office (121)	<1.00	15.5	No
53 GRHS-1FL-WCC-Mens LR (121)	<1.00	15.5	No
54 GRHS-1FL-FB2-O/S 115	<1.00	15.5	No
55 GRHS-1FL-WCF-Office A101A	<1.00	15.5	No
56 GRHS-1FL-WCC-Cafeteria	<1.00	15.5	No
57 GRHS-1FL-IMM-Kitchen	<1.00	15.5	No
58 GRHS-1FL-CM-Cafeteria	<1.00	15.5	No
59 GRHS-1FL-CF5-Kitchen	117	15.5	Yes
60 GRHS-1FL-CF4-Kitchen	<1.00	15.5	No
61 GRHS-1FL-CF3-Kitchen	<1.00	15.5	No
62 GRHS-1FL-CF2-Kitchen	<1.00	15.5	No
63 GRHS-1FL-CF1-Kitchen	<1.00	15.5	No
64 GRHS-2FL-WCF-Teacher's Lounge (235)	<1.00	15.5	No
65 GRHS-2FL-WC1-O/S 231	<1.00	15.5	No
66 GRHS-2FL-WC2-O/S 216	<1.00	15.5	No
67 GRHS-2FL-WCF-Teachers' Lounge (216)	1.84	15.5	No
68 GRHS-2FL-WC3-O/S A209	<1.00	15.5	No
69 GRHS-2FL-WC2-O/S A209	<1.00	15.5	No
70 GRHS-2FL-WCC-O/S 236B	<1.00	15.5	No
71 GRHS-3FL-WC3-O/S A310	<1.00	15.5	No
72 GRHS-3FL-WC2-O/S A310	<1.00	15.5	No
73 GRHS-3FL-WC1-O/S A310	<1.00	15.5	No
74 Field Blank	<1.00	15.5	No

-END OF SECTION-



3.0 SAMPLING AND ANALYSES

The following guidance documents were followed for all sampling:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Seventy three (73) first draw samples, along with one field blank for quality control purposes, were collected.

All samples were labeled with a unique identification number and transported to the Suburban Laboratory for analysis for lead in drinking water using EPA Method 200.8.

-END OF SECTION-

4.0 DISCUSSION & RECOMMENDATIONS

According to the US EPA, lead enters drinking water primarily through plumbing materials.

For further information on guidance protocols and Action Levels that were followed please refer to:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Based on laboratory analysis of the samples analyzed, one (1) sample exceeded the action limit.

Immediate / Short Term Action Required:

1. Immediately discontinue using water at locations exceeding the NJDEP 15.5 ppb Action Level.
2. The follow-up flush sample for the outlet that exceeded needs to be collected and analyzed.
3. Refer to EPA's "**for Reducing Lead in Drinking Water in Schools and Child Care Facilities**" for other short term and long term suggested remediation measures and notification procedures.

The type of samples collected for this assessment are referred to as grab samples. Grab samples are individual discrete samples collected at a specific time and location and are reflective of the conditions at that time of collection.

It is important to note that the Lead Hazard Assessment was a snap shot of the conditions existing at the time of the assessment and conditions may vary with time.

-END OF SECTION-



5.0 DISCLAIMER

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment only.

Westchester Environmental LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for, and is confidential to, the above noted client. Westchester Environmental LLC assumes no liability with regards to the use of this information or decisions, which are made regarding the subject property. The user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', followed by a horizontal line.

Noel Abraham
Environmental Specialist

-END OF REPORT-

APPENDIX I

**LEAD IN DRINKING WATER SAMPLING
CHAINS-OF-CUSTODY & LAB REPORTS**



Results Report

Order ID: 1K02811

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: Glen Ridge SD
12 High St
Glen Ridge, NJ

Attn: Noel Abraham

Regulatory ID:

Sample Number: 1K02811-01
Collector:

Site: GRC-POE-Nurse
Collect Date: 11/04/2021 1:53 pm

Sample ID: Nurse
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/11/21 MKR 11/24/21 11:16 RPV

Sample Number: 1K02811-02
Collector:

Site: GRC-1FL-NS-Nurse
Collect Date: 11/04/2021 1:55 pm

Sample ID: Nurse
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/11/21 MKR 11/24/21 10:57 RPV

Sample Number: 1K02811-03
Collector:

Site: GRC-1FL-BF-O/S Nurse - 2
Collect Date: 11/04/2021 1:57 pm

Sample ID: O/S Nurse - 2
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/11/21 MKR 11/24/21 11:14 RPV

Sample Number: 1K02811-04
Collector:

Site: GRC-1FL-BF-O/S Handicap BR-
Collect Date: 11/04/2021 1:59 pm

Sample ID: O/S Handicap BR-
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/11/21 MKR 11/24/21 11:09 RPV

Sample Number: 1K02811-05
Collector:

Site: GRC-1FL-FS-Teacher's Lounge
Collect Date: 11/04/2021 2:00 pm

Sample ID: Teacher's Lounge
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/11/21 MKR 11/24/21 11:08 RPV

Report Generated On: 11/29/2021 10:12 am 1K02811
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-06	Site: GRLE-B-POE-B2	Sample ID: B2
Collector:	Collect Date: 11/04/2021 2:11 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:05	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-07	Site: GRLE-B-WCC-O/S BOILER RM	Sample ID: O/S BOILER RM
Collector:	Collect Date: 11/04/2021 2:13 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:25	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-08	Site: GRLE-WCF-Nurse (B5)	Sample ID: Nurse (B5)
Collector:	Collect Date: 11/04/2021 2:15 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:24	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-09	Site: GRLE-B-WCF-Cr 16W	Sample ID: Cr 16W
Collector:	Collect Date: 11/04/2021 2:16 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.95	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:22	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-10	Site: GRLE-1FL-WCF-Cr 17W	Sample ID: Cr 17W
Collector:	Collect Date: 11/04/2021 2:17 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:21	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-11	Site: GRLE-1FL-WCF-Cr 6	Sample ID: Cr 6
Collector:	Collect Date: 11/04/2021 2:18 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:19	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-12	Site: GRLE-1FL-WCF-Cr 6 BR	Sample ID: Cr 6 BR
Collector:	Collect Date: 11/04/2021 2:19 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.36	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:17	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-13	Site: GRLE-1FL-WCC-O/S CR 1	Sample ID: O/S CR 1
Collector:	Collect Date: 11/04/2021 2:20 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:38	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-14	Site: GRLE-1FL-WCF-CR 3	Sample ID: CR 3
Collector:	Collect Date: 11/04/2021 2:21 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.34	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:37	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-15	Site: GRLE-1FL-WCF-CR 3 BR	Sample ID: CR 3 BR
Collector:	Collect Date: 11/04/2021 2:22 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.22	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:35	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-16	Site: GRLE-GRLE-1FL-WCF-CR 4	Sample ID: CR 4
Collector:	Collect Date: 11/04/2021 2:23 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:33	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-17	Site: GRLE-1FL-WCF-CR 5	Sample ID: CR 5
Collector:	Collect Date: 11/04/2021 2:24 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:29	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-18	Site: GRLE-2FL-WCF-Teachers Lounge	Sample ID: Teacher's Lounge
Collector:	Collect Date: 11/04/2021 2:25 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:01	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-19	Site: GRLE-2FL-WCC-O/S Teachers Lounge	Sample ID: O/S Teachers Lounge
Collector:	Collect Date: 11/04/2021 2:26 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:06	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-20	Site: GRLE-2FL-WCF-CR 14	Sample ID: CR 14
Collector:	Collect Date: 11/04/2021 2:27 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/24/21 11:27	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-21	Site: GRFE--POE-Gym CF1GRFE--POE-Gym	Sample ID: Gym CF1
Collector:	Collect Date: 11/04/2021 2:45 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:26	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-22	Site: GRFE-B-WCC-Gym	Sample ID: Gym
Collector:	Collect Date: 11/04/2021 2:46 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:58	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-23	Site: GRFE-B-WCF-Exit 2	Sample ID: Exit 2
Collector:	Collect Date: 11/04/2021 2:47 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 9:00	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-24	Site: GRFE-1FL-WCF-W4	Sample ID: W4
Collector:	Collect Date: 11/04/2021 2:48 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 9:05	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-25	Site: GRFE-1FL-WCF-W3	Sample ID: W3
Collector:	Collect Date: 11/04/2021 2:49 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 9:07	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-26	Site: GRFE-1FL-WCF-W2	Sample ID: W2
Collector:	Collect Date: 11/04/2021 2:50 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	11.1	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 9:08	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-27	Site: GRFE-1FL-WCF-W1	Sample ID: W1
Collector:	Collect Date: 11/04/2021 2:51 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:56	RPV

Sample Number: 1K02811-28	Site: GRFE-1FL-WCC-O/S W1	Sample ID: O/S W1
Collector:	Collect Date: 11/04/2021 2:53 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:55	RPV

Sample Number: 1K02811-29	Site: GRFE-2FL-WCC-O/S 9	Sample ID: O/S 9
Collector:	Collect Date: 11/04/2021 2:54 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:50	RPV

Sample Number: 1K02811-30	Site: GRA-Bsmt-POE-Slop Sink	Sample ID: Basement Slop Sink
Collector:	Collect Date: 11/04/2021 3:12 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	2.29	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:52	RPV

Sample Number: 1K02811-31	Site: GRA-1FL-WCF-1st FI	Sample ID: 1st FI
Collector:	Collect Date: 11/04/2021 3:15 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	1.01	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:53	RPV

Sample Number: 1K02811-32	Site: GRA-3FI-WCF-3rd FI	Sample ID: 3rd FI
Collector:	Collect Date: 11/04/2021 3:16 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:45	RPV

Sample Number: 1K02811-33	Site: GRRE-B-POE-Art	Sample ID: Art
Collector:	Collect Date: 11/04/2021 3:28 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:47	RPV

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-34	Site: GRRE-B-WCC-O/S Gym	Sample ID: O/S Gym
Collector:	Collect Date: 11/04/2021 3:30 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:48	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-35	Site: GRRE-B-WCF-Teachers Lounge (20)	Sample ID: Teachers Lounge (20)
Collector:	Collect Date: 11/04/2021 3:32 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:37	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-36	Site: GRRE-Mez-WCC-O/S Gym	Sample ID: O/S Gym
Collector:	Collect Date: 11/04/2021 3:34 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:39	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-37	Site: GRRE-1FL-WCF-Nurse	Sample ID: Nurse
Collector:	Collect Date: 11/04/2021 3:36 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:40	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-38	Site: GRRE-1FL-WCF-Office 101	Sample ID: Office 101
Collector:	Collect Date: 11/04/2021 3:38 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:31	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-39	Site: GRRE-1FL-WCC-O/S 123	Sample ID: O/S 123
Collector:	Collect Date: 11/04/2021 3:40 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:34	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-40	Site: GRRE-2FL-WCC-O/S 222	Sample ID: O/S 222
Collector:	Collect Date: 11/04/2021 3:42 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/11/21	MKR	11/22/21 8:36	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-41	Site: GRRE-2FL-WCC-O/S 208	Sample ID: O/S 208
Collector:	Collect Date: 11/04/2021 3:44 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 9:19	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-42	Site: GRRE-2FL-WC1-Café - 1	Sample ID: Café - 1
Collector:	Collect Date: 11/04/2021 3:46 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:13	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-43	Site: GRRE-2FL-S-Café - 2	Sample ID: Café - 2
Collector:	Collect Date: 11/04/2021 3:48 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:14	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-44	Site: GRRE-2FL-CF1-Kitchen - 1	Sample ID: Kitchen - 1
Collector:	Collect Date: 11/04/2021 3:50 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:16	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-45	Site: GRRE-2FL-CF1-Kitchen - 2	Sample ID: Kitchen - 2
Collector:	Collect Date: 11/04/2021 3:52 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	7.97	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:17	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-46	Site: GRRE-2FL-CF1-Kitchen - 3	Sample ID: Kitchen - 3
Collector:	Collect Date: 11/04/2021 3:54 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:29	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-47	Site: GRRE-2FL-CF1-Kitchen - 5	Sample ID: Kitchen - 5
Collector:	Collect Date: 11/04/2021 3:56 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:09	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-48	Site: GRRE-2FL-CF1-Kitchen - 6	Sample ID: Kitchen - 6
Collector:	Collect Date: 11/04/2021 3:58 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:11	RPV

Sample Number: 1K02811-49	Site: GRRE-2FL-CF1-Kitchen - 7	Sample ID: Kitchen - 7
Collector:	Collect Date: 11/04/2021 4:00 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:21	RPV

Sample Number: 1K02811-50	Site: GRHS-B-POE-Art Sink	Sample ID: Art Sink
Collector:	Collect Date: 11/04/2021 4:11 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:22	RPV

Sample Number: 1K02811-51	Site: GRHS-1FL-WCF-Nurse (121)	Sample ID: Nurse (121)
Collector:	Collect Date: 11/04/2021 4:12 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 9:18	RPV

Sample Number: 1K02811-52	Site: GRHS-1FL-WCF-Office (121)	Sample ID: Office (121)
Collector:	Collect Date: 11/04/2021 4:13 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:30	RPV

Sample Number: 1K02811-53	Site: GRHS-1FL-WCC-Mens LR (121)	Sample ID: Mens LR (121)
Collector:	Collect Date: 11/04/2021 4:14 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/17/21	RPV	11/23/21 17:01	RPV

Sample Number: 1K02811-54	Site: GRHS-1FL-FB2-O/S 115	Sample ID: O/S 115
Collector:	Collect Date: 11/04/2021 4:15 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:19	RPV

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-55	Site: GRHS-1FL-WCF-Office A101A	Sample ID: Office A101A
Collector:	Collect Date: 11/04/2021 4:16 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:35	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-56	Site: GRHS-1FL-WCC-Cafeteria	Sample ID: Cafeteria
Collector:	Collect Date: 11/04/2021 4:17 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:38	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-57	Site: GRHS-1FL-IMM-Kitchen	Sample ID: Kitchen
Collector:	Collect Date: 11/04/2021 4:18 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:37	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-58	Site: GRHS-1FL-CM-Cafeteria	Sample ID: Cafeteria
Collector:	Collect Date: 11/04/2021 4:19 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/19/21 14:42	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-59	Site: GRHS-1FL-CF5-Kitchen	Sample ID: Kitchen
Collector:	Collect Date: 11/04/2021 4:20 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	117	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:32	RPV
------	-----	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-60	Site: GRHS-1FL-CF4-Kitchen	Sample ID: Kitchen
Collector:	Collect Date: 11/04/2021 4:21 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	RPV	11/22/21 7:33	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1K02811-61	Site: GRHS-1FL-CF3-Kitchen	Sample ID: Kitchen
Collector:	Collect Date: 11/04/2021 4:22 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:13	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1K02811-62	Site: GRHS-1FL-CF2-Kitchen	Sample ID: Kitchen
Collector:	Collect Date: 11/04/2021 4:23 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:34	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-63	Site: GRHS-1FL-CF1-Kitchen	Sample ID: Kitchen
Collector:	Collect Date: 11/04/2021 4:24 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:32	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-64	Site: GRHS-2FL-WCF-Teacher's Lounge (235)	Sample ID: Teacher's Lounge (235)
Collector:	Collect Date: 11/04/2021 4:25 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 13:36	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-65	Site: GRHS-2FL-WC1-O/S 231	Sample ID: O/S 231
Collector:	Collect Date: 11/04/2021 4:26 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:31	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-66	Site: GRHS-2FL-WC2-O/S 216	Sample ID: O/S 216
Collector:	Collect Date: 11/04/2021 4:27 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:29	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-67	Site: GRHS-2FL-WCF-Teachers Lounge (216)	Sample ID: Teachers Lounge (216)
Collector:	Collect Date: 11/04/2021 4:28 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.84	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:35	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-68	Site: GRHS-2FL-WC3-O/S A209	Sample ID: O/S A209
Collector:	Collect Date: 11/04/2021 4:29 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:43	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/29/2021 10:12 am 1K02811
 STL_Results Revision #1.9 Effective: 04/16/2020





Sample Number: 1K02811-69	Site: GRHS-2FL-WC2-O/S A209	Sample ID: O/S A209
Collector:	Collect Date: 11/04/2021 4:30 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:42	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-70	Site: GRHS-2FL-WCC-O/S 236B	Sample ID: O/S 236B
Collector:	Collect Date: 11/04/2021 4:31 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:40	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-71	Site: GRHS-3FL-WC3-O/S A310	Sample ID: O/S A310
Collector:	Collect Date: 11/04/2021 4:32 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:39	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-72	Site: GRHS-3FL-WC2-O/S A310	Sample ID: O/S A310
Collector:	Collect Date: 11/04/2021 4:33 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:37	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-73	Site: GRHS-3FL-WC1-O/S A310	Sample ID: O/S A310
Collector:	Collect Date: 11/04/2021 4:34 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:48	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K02811-74	Site: Field Blank	Sample ID: Field Blank
Collector:	Collect Date: 11/04/2021 4:35 pm	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/16/21 12:17	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 11/29/2021 10:12 am 1K02811
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 11/29/2021 10:12 am 1K02811
STL_Results Revision #1.9 Effective: 04/16/2020





COC Pg 1

1K02811
Lisa F. Care



Chain of Custody Record

TAT (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.		Project Name:	Glen Ridge SD	
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	All Buildings
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com	Payment / P.O. Info:	12 High St., Glen Ridge, NJ
Contact Name:	Noel Abraham				

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	GRC--POE-Nurse	11/04/21	01:53 PM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	GRC-1FL-NS-Nurse	11/04/21	01:55 PM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	GRC-1FL-BF-O/S Nurse - 2	11/04/21	01:57 PM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	O/S Nurse - 2
First	GRC-1FL-BF-O/S Handicap BR-	11/04/21	01:59 PM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	O/S Handicap BR-
First	GRC-1FL-FS-Teacher's Lounge	11/04/21	02:00 PM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	Teacher's Lounge
Flush	GRLE-B-POE-B2	11/04/21	02:11 PM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	B2
First	GRLE-B-WCC-O/S BOILER R	11/04/21	02:13 PM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	O/S BOILER RM
First	GRLE-B-WCF-Nurse (B5)	11/04/21	02:15 PM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	Nurse (B5)
First	GRLE-1FL-WCF-Cr 16W	11/04/21	02:16 PM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	Cr 16W
First	GRLE-1FL-WCF-Cr 17W	11/04/21	02:17 PM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	Cr 17W

Relinquished by: *J.M.W.* Date: _____ Time: _____

Received By: *GAH - GFL* Date: *11-9-21* Temp °C: *22.2*
Time: *10:00* Acceptable Y / N

Relinquished by: *GAH - STR* Date: *11-9-21* Temp °C: *19.0*
Time: *10:30* Acceptable Y / N

Received in Lab By: *CB* Date: *11-9-21* Temp °C: *19.0*
Time: *15:30* Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ CDC	NPW = Non-Potable Water	P = Plastic
Sealed w/ Raw Sample, Decontaminated, Disinfectant, etc. (Preserved as right)	PW = Possible Water	G = Glass
Sealed w/ Disinfectant, etc. (Preserved as right)	SWDA = Safe Drinking Water Act	C = Other
All containers intact	Possible Bacteria	Preservative Key
Tests within holding times	Sample Type Key (SWDA Sample Type)	H = Sodium
90 ml VDA vials free of headspace?	G = Grab	Acid
	SWC = 8 Hour	A = Ascorbic
	Composites	H = HNO3
	24 HC = 24 Hour Composite	C = HCl
		M = H2SO4
		Q = Other
		None Required
		NA = None

(10) 250ml P + HNO3



1K02811
Lisa F. Care



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

1A1 (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Glen Ridge SD		
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	All Buildings		
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		12 High St., Glen Ridge, NJ		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	GRLE-1FL-WCF-Cr 6	11/04/21	02:18 PM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	Cr 6
First	GRLE-1FL-WCF-Cr 6 BR	11/04/21	02:19 PM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	Cr 6 BR
First	GRLE-1FL-WCC-O/S CR 1	11/04/21	02:20 PM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	O/S CR 1
First	GRLE-1FL-WCF-CR 3	11/04/21	02:21 PM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	CR 3
First	GRLE-1FL-WCF-CR 3 BR	11/04/21	02:22 PM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	CR 3 BR
First	GRLE-1FL-WCF-CR 4	11/04/21	02:23 PM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	CR 4
First	GRLE-1FL-WCF-CR 5	11/04/21	02:24 PM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	CR 5
First	GRLE-2FL-WCF-Teachers Lounge	11/04/21	02:25 PM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	Teachers Lounge
First	GRLE-2FL-WCC-O/S Teachers Lo	11/04/21	02:26 PM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	O/S Teachers Lounge
First	GRLE-2FL-WCF-CR 14	11/04/21	02:27 PM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	CR 14

Relinquished by: *BCH* Date: _____ Time: _____

Received By: *LSL-GTC* Date: *11-9-21* Temp °C: *22* Acceptable N

Relinquished by: *BCH* Date: *11-9-21* Temp °C: *19* Acceptable N

Received in Lab By: *CB* Date: *11-9-21* Temp °C: *19* Acceptable N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ CDC	NEW = Non-Potable Water	P = Plastic
Method of collection	SWA = Safe Drinking Water Act	G = Glass
All containers used	Sample Type Key	Other
Tap water (not for SWA compliance)	G = Grab	H = Sodium Hydroxide
40 ml VOA vials (not for SWA compliance)	D = Distribution	A = Ascorbic Acid
	Q = Quota	H = HCl
	S = Siphon	M = H2O2
	C = Check	O = Other
	S = Swab	
	M = Mixtures	
	R = Residue	

(10) 250ML P + HNO3



1K02811
Lisa F. Care



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Glen Ridge SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	All Buildings
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		12 High St., Glen Ridge, NJ
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	GRFE--POE-Gym CF1	11/04/21	02:45 PM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	Gym CF1
First	GRFE-B-WCC-Gym	11/04/21	02:46 PM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	Gym
First	GRFE-B-WCF-Exit 2	11/04/21	02:47 PM	NPA	023	Pb EPA 200.8	1	PW	G	P	H	Exit 2
First	GRFE-1FL-WCF-W4	11/04/21	02:48 PM	NPA	024	Pb EPA 200.8	1	PW	G	P	H	W4
First	GRFE-1FL-WCF-W3	11/04/21	02:49 PM	NPA	025	Pb EPA 200.8	1	PW	G	P	H	W3
First	GRFE-1FL-WCF-W2	11/04/21	02:50 PM	NPA	026	Pb EPA 200.8	1	PW	G	P	H	W2
First	GRFE-1FL-WCF-W1	11/04/21	02:51 PM	NPA	027	Pb EPA 200.8	1	PW	G	P	H	W1
First	GRFE-1FL-WCC-O/S W1	11/04/21	02:53 PM	NPA	028	Pb EPA 200.8	1	PW	G	P	H	O/S W1
First	GRFE-2FL-WCC-O/S 9	11/04/21	02:54 PM	NPA	029	Pb EPA 200.8	1	PW	G	P	H	O/S 9
Flush	GRA-Bsmt-POE-Slop Sink	11/04/21	03:12 PM	NPA	030	Pb EPA 200.8	1	PW	G	P	H	Basement Slop Sink

Relinquished by: *JRH* Date: _____ Time: _____
 Received By: _____ Date: *11-9-21* Temp °C: *22.9C*
OTAR - JTL Time: *12:00* Acceptable: *Y/N*
 Relinquished by: _____ Date: *11-9-21* Temp °C: *19.0C*
CKM - JTL Time: *15:30* Acceptable: *Y/N*
 Received in Lab By: _____ Date: *11-9-21* Temp °C: *19.0C*
CB Time: *15:30* Acceptable: *Y/N*

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <i>Y/N</i> Alternate to container's matrix <i>Y/N</i> Residual no. PPM < _____ All containers intact <i>Y/N</i> Tests within holding times <i>Y/N</i> All ml. VOA vials free of preservative? <i>Y/N</i>	NPW = Non Potable Water Solid = Raw Sludge, Sewer/Solid Sludge, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8 HC = 8 Hour Composites 24 HC = 24 Hour Composites H = Heterogeneous E = Empty Pallet R = Rack C = Chilled S = Special M = Minimum Residence	P = Plastic G = Glass O = Other Preservative Key H = Sodium Thiosulfate A = Ascorbic Acid C = HCl HClO ₂ O = Other None Required A = Ascorbic H = HNE30 S = CH = NaOH NA =

(10) 250ML P + HNO3



1K02811
Lisa F. Care



Chain of Custody Record

TAT (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.		Project Name:	Glen Ridge SD	
Address:	1248 Wrights Lane	Phone:	410-431-7545		
	West Chester, PA 19380	Email:	nabraham@westchesterenvironmental.com		
Contact Name:	Noel Abraham	Address:	All Buildings 12 High St., Glen Ridge, NJ		
		Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	GRA-1FL-WCF-1st FI	11/04/21	03:15 PM	NPA	031	Pb EPA 200.8	1	PW	G	P	H	1st FI
First	GRA-3FI-WCF-3rd FI	11/04/21	03:16 PM	NPA	032	Pb EPA 200.8	1	PW	G	P	H	3rd FI
Flush	GRRE-B-POE-Art	11/04/21	03:28 PM	NPA	033	Pb EPA 200.8	1	PW	G	P	H	Art
First	GRRE-B-WCC-O/S Gym	11/04/21	03:30 PM	NPA	034	Pb EPA 200.8	1	PW	G	P	H	O/S Gym
First	GRRE-B-WCF-Teachers Lounge	11/04/21	03:32 PM	NPA	035	Pb EPA 200.8	1	PW	G	P	H	Teachers Lounge (20)
First	GRRE-Mez-WCC-O/S Gym	11/04/21	03:34 PM	NPA	036	Pb EPA 200.8	1	PW	G	P	H	O/S Gym
First	GRRE-1FL-WCF-Nurse	11/04/21	03:36 PM	NPA	037	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	GRRE-1FL-WCF-Office 10	11/04/21	03:38 PM	NPA	038	Pb EPA 200.8	1	PW	G	P	H	Office 101
First	GRRE-1FL-WCC-O/S 123	11/04/21	03:40 PM	NPA	039	Pb EPA 200.8	1	PW	G	P	H	O/S 123
First	GRRE-2FL-WCC-O/S 222	11/04/21	03:42 PM	NPA	040	Pb EPA 200.8	1	PW	G	P	H	O/S 222

Relinquished by: *BRH* Date: Time: Temp °C: Acceptable (Y) / N

Received By: *GR - GTC* Date: 11-9-21 Temp °C: 72 °C Acceptable (Y) / N

Relinquished by: *GR - 5TC* Date: 11-9-21 Temp °C: 19 °C Acceptable (Y) / N

Received in Lab By: *CB* Date: 11-9-21 Temp °C: 19 °C Acceptable (Y) / N

Time: 1530 *ITC*

Sample Conditions	Matrix Key	Bottle Type Key
Number of (CFE) <input checked="" type="checkbox"/> N Number of (CFE) <input type="checkbox"/> N All containers intact <input checked="" type="checkbox"/> N Tests within holding times <input checked="" type="checkbox"/> N All test WDA valid (incl. of heterotrophic) <input checked="" type="checkbox"/> N	Matrix Key PW = Potable Water SDWA = Safe Drinking Water Act Potable Sample Sample Type Key (SDWA Sample Type) G = Grab B HC = 6 Hour Composite 24 HC = 24 Hour Composite DI = Distribution EP = Entry Point F = Flow C = Check S = Special M = Maximum Concentration	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key H = Sodium Thiosulfate A = Ascorbic Acid H = HNO3 S = HCl O = No Preservative NA = None Required

(10) 2 same P + HNO3.



1K02811
Lisa F. Care



Chain of Custody Record

IAI (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Glen Ridge SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	All Buildings
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		12 High St., Glen Ridge, NJ
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	GRRE-2FL-WCC-O/S 208	11/04/21	03:44 PM	NPA	041	Pb EPA 200.8	1	PW	G	P	H	O/S 208
First	GRRE-2FL-WC1-Café - 1	11/04/21	03:46 PM	NPA	042	Pb EPA 200.8	1	PW	G	P	H	Café - 1
First	GRRE-2FL-S-Café - 2	11/04/21	03:48 PM	NPA	043	Pb EPA 200.8	1	PW	G	P	H	Café - 2
First	GRRE-2FL-CF1-Kitchen - 1	11/04/21	03:50 PM	NPA	044	Pb EPA 200.8	1	PW	G	P	H	Kitchen - 1
First	GRRE-2FL-CF2-Kitchen - 2	11/04/21	03:52 PM	NPA	045	Pb EPA 200.8	1	PW	G	P	H	Kitchen - 2
First	GRRE-2FL-CF3-Kitchen - 3	11/04/21	03:54 PM	NPA	046	Pb EPA 200.8	1	PW	G	P	H	Kitchen - 3
First	GRRE-2FL-CF4-Kitchen - 5	11/04/21	03:56 PM	NPA	047	Pb EPA 200.8	1	PW	G	P	H	Kitchen - 5
First	GRRE-2FL-CF5-Kitchen - 6	11/04/21	03:58 PM	NPA	048	Pb EPA 200.8	1	PW	G	P	H	Kitchen - 6
First	GRRE-2FL-IM-Kitchen - 7	11/04/21	04:00 PM	NPA	049	Pb EPA 200.8	1	PW	G	P	H	Kitchen - 7
Flush	GRHS-B-POE-Art Sink	11/04/21	04:11 PM	NPA	050	Pb EPA 200.8	1	PW	G	P	H	Art Sink

Relinquished by: *GRB* Date: Time: Temp: °C

Received By: *GRB - STC* Date: *11-9-21* Temp: °C: *22* Acceptable N

Relinquished by: *GRB - STC* Date: *11-9-21* Temp: °C: *19* Acceptable N

Received in Lab By: *CB* Date: *11-9-21* Temp: °C: *19* Acceptable N

Time: *1530* *IR*

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Substrate or DOC: <input checked="" type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic	SWDA Reporting <input type="checkbox"/>
Residuals or containers match: <input checked="" type="checkbox"/> N	Solid = Raw Sludge, Dewatered Sludge, etc. (reported as mg/L)	G = Glass	Pb/As <input type="checkbox"/>
All containers intact: <input checked="" type="checkbox"/> N	PW = Potable Water (not for SWDA compliance)	Other	Free <input type="checkbox"/>
Tests within holding times: <input checked="" type="checkbox"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	Email <input type="checkbox"/>
All mt. VQA vials free of headspace? <input checked="" type="checkbox"/> N	Sample Type Key	H = Sodium Thiosulfate	Other <input type="checkbox"/>
	SWDA Sample Type	Acid	
	G = Gals	H ₂ O ₂	
	E = Empty Point	Other	
	R = Raw	None Required	
	C = Check		
	S = Special		
	24 HC = 24 Hour Composite		
	M = Madman		
	Residence		

(10) 250ML P + HNO3.



1K02811
Lisa F. Care



TESTING LABS

Chain of Custody Record

IA1 (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Glen Ridge SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	All Buildings
	West Chester, PA 19380	Email:	nabraham@westchesterenvironmental.com		12 High St., Glen Ridge, NJ
Contact Name:	Noel Abraham	Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First ✓	GRHS-1FL-WCF-Nurse (12)	11/04/21	04:12 PM	NPA	051	Pb EPA 200.8	1	PW	G	P	H	Nurse (121)
First ✓	GRHS-1FL-WCF-Office (121)	11/04/21	04:13 PM	NPA	052	Pb EPA 200.8	1	PW	G	P	H	Office (121)
First ✓	GRHS-1FL-WCC-Mens LR (121)	11/04/21	04:14 PM	NPA	053	Pb EPA 200.8	1	PW	G	P	H	Mens LR (121)
First ✓	GRHS-1FL-FB2-O/S 115	11/04/21	04:15 PM	NPA	054	Pb EPA 200.8	1	PW	G	P	H	O/S 115
First ✓	GRHS-1FL-WCF-Office A101A	11/04/21	04:16 PM	NPA	055	Pb EPA 200.8	1	PW	G	P	H	Office A101A
First ✓	GRHS-1FL-WCC-Cafeteria	11/04/21	04:17 PM	NPA	056	Pb EPA 200.8	1	PW	G	P	H	Cafeteria
First ✓	GRHS-1FL-IMM-Kitchen	11/04/21	04:18 PM	NPA	057	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First ✓	GRHS-1FL-CM-Cafeteria	11/04/21	04:19 PM	NPA	058	Pb EPA 200.8	1	PW	G	P	H	Cafeteria
First ✓	GRHS-1FL-CF5-Kitchen	11/04/21	04:20 PM	NPA	059	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First ✓	GRHS-1FL-CF4-Kitchen	11/04/21	04:21 PM	NPA	060	Pb EPA 200.8	1	PW	G	P	H	Kitchen

Relinquished by: *GAH* Date: _____
 Time: _____

Received by: *GAH - STL* Date: *11-9-21* Temp °C: *28.0*
 Time: *12:00* Acceptable *Y/N*

Relinquished by: *GAH - STL* Date: *11-9-21* Temp °C: *14.0*
 Time: *15:30* Acceptable *Y/N*

Received in Lab by: *CB* Date: *11-9-21* Temp °C: *19.0*
 Time: *15:30* Acceptable *Y/N*
for

Sample Conditions	Matrix Key	Bottle Type Key
Submitted in CDC container to containers match container for CDC? <i>Y/N</i>	NPW = Non-Potable Water Sludge, soil, etc. (reported as mg/L)	P = Plastic G = Glass O = Other
All containers sealed <i>Y/N</i>	PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	Preservative Key H = Sodium Thresholds: A = Ascorbic Acid, B = HClO, C = HClO, D = NaClO, E = None Required
Tests within holding time <i>Y/N</i>	Sample Type Key G = Gas S = Solid C = Check S = Special M = Maximum Residues	SWDA Sample Type 1 = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residues
All test WDA state free of tampering? <i>Y/N</i>	24-HC = 24 Hour Composites	

(10) 250 mL P + HNO3



1K02811
Lisa F. Care



Chain of Custody Record

IAI (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Glen Ridge SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	All Buildings
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		12 High St., Glen Ridge, NJ
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	GRHS-1FL-CF3-Kitchen	11/04/21	04:22 PM	NPA	61	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	GRHS-1FL-CF2-Kitchen	11/04/21	04:23 PM	NPA	62	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	GRHS-1FL-CF1-Kitchen	11/04/21	04:24 PM	NPA	63	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	GRHS-2FL-WCF-Teacher's Lounge	11/04/21	04:25 PM	NPA	64	Pb EPA 200.8	1	PW	G	P	H	Teacher's Lounge (235)
First	GRHS-2FL-WC1-O/S 231	11/04/21	04:26 PM	NPA	65	Pb EPA 200.8	1	PW	G	P	H	O/S 231
First	GRHS-2FL-WC2-O/S 216	11/04/21	04:27 PM	NPA	66	Pb EPA 200.8	1	PW	G	P	H	O/S 216
First	GRHS-2FL-WCF-Teachers Lounge	11/04/21	04:28 PM	NPA	67	Pb EPA 200.8	1	PW	G	P	H	Teachers Lounge (216)
First	GRHS-2FL-WC3-O/S A209	11/04/21	04:29 PM	NPA	68	Pb EPA 200.8	1	PW	G	P	H	O/S A209
First	GRHS-2FL-WC2-O/S A209	11/04/21	04:30 PM	NPA	69	Pb EPA 200.8	1	PW	G	P	H	O/S A209
First	GRHS-2FL-WCC-O/S 236B	11/04/21	04:31 PM	NPA	70	Pb EPA 200.8	1	PW	G	P	H	O/S 236B

Relinquished by: *JNH* Date: _____ Time: _____
 Received By: *CBM - STC* Date: *11-9-21* Temp °C: *72* °C
 Relinquished by: *CBM - STC* Date: *11-9-21* Temp °C: *19* °C
 Received in Lab By: *CB* Date: *11-9-21* Temp °C: *19* °C
 Time: *1530* Acceptable N

Sample Conditions	Matrix Key	Bottle Type Key
Substrate of GOC <input checked="" type="checkbox"/> N	PW = Tap/Potable Water	P = Plastic
Material in container (check transfer to label) <input checked="" type="checkbox"/> N	SW = Raw Sewage, Sewerage, Sludge, soil, etc. (reported as soil)	G = Glass
All containers clean <input checked="" type="checkbox"/> N	PW = Potable Water (not for SWDA compliance)	OT = Other
Tests with holding times <input checked="" type="checkbox"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
50 ml VOA state free of headspace? <input checked="" type="checkbox"/> N	Sample Type Key	H = Acidic
	G = Grab	A = Ascorbic Acid
	CHC = 24hr Composite	H = HNO3
	Composite	E = HCl
	C = Chilled	N2O2
	S = Source	Cl = NaCl
	M = Maximum	NA = None Required
	Composite	
	Preservative	

(10) 250ml P + HNO3



1K02811
Lisa F. Care



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.		Project Name:	Glen Ridge SD	
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	All Buildings
	West Chester, PA 19380				12 High St., Glen Ridge, NJ
Contact Name:	Noel Abraham	Email:	nabraham@westchesterenvironmental.com	Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	GRHS-3FL-WC3-O/S A310	11/04/21	04:32 PM	NPA	071	Pb EPA 200.8	1	PW	G	P	H	O/S A310
First	GRHS-3FL-WC2-O/S A310	11/04/21	04:33 PM	NPA	072	Pb EPA 200.8	1	PW	G	P	H	O/S A310
First	GRHS-3FL-WC1-O/S A310	11/04/21	04:34 PM	NPA	073	Pb EPA 200.8	1	PW	G	P	H	O/S A310
First	Field Blank	11/04/21	04:35 PM	NPA	074	Pb EPA 200.8	1	PW	G	P	H	Field Blank

Relinquished by: *ANB* Date: _____ Time: _____
 Received By: *GM-9TC* Date: *11-9-21* Temp °C: *8.8*
 Time: *12:00* Acceptable? *(X) N*
 Relinquished by: _____ Date: *11-9-21* Temp °C: *19.0*
 Received in Lab By: *CB* Date: *11-9-21* Temp °C: *19.0*
 Time: *1:53* Acceptable? *(X) N*
Ice

Sample Conditions	Matrix Key	Bottle Type Key
Submitted as C/C?	NPTW = Non-Potable Water	P = Plastic
Inspected for container match?	Solid = Flow Meter (unfiltered)	G = Glass
Inspected for leaks?	Sludge sol. etc. (reported on tag)	Q = Other
All containers intact?	PW = Potable Water	Preservative Key
Tests within holding time?	SDWA = Safe Drinking Water Act	H = Sodium
40 ml WQA vials for of benzene?	Relabel Sample	Thiosulfate
	Sample Type Key / SDWA Sample Type	A = Ascorbic Acid
	G = Grab	H = HNO3
	24 HC = 24 Hour Composite	C = HCl
	D = Distillate	H2SO4
	E = Entry Point	Q = Other
	F = Filter	None Prepared
	G = Check	
	S = Specific	
	M = Maximum Residence	

(4) 250ml P + HNO3